

STATEMENT OF BASIS
Permit Modification
Permit No. WA0040819
Domsea Broodstock

Domsea Broodstock has begun chlorination of the effluent discharge at the Carlson facility. Chlorine is a limited substance. The standard permit sets a limit for the discharge of chlorinated water from disinfected rearing ponds at a concentration of 19 µg/L. This limit will be taken as AKART for the discharge from the Carlson facility. Testing procedures are stated in Special Condition S2B. Since this level of concentration is quite low, the installation of dechlorination equipment will be necessary. The permittee must purchase and install dechlorination equipment within six months of the issuance of the permit modification.

Sampling and reporting for seasonal limits (BOD, Ammonia, and Phosphorus) has been clarified.